



Government of Tripura
Directorate General of Fire Service
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: dfireservicetripura@gmail.com.

Website: www.fireservice.tripura.gov

No. 3-8/JFS/2019/ 6817-19

Dated, Agartala, the 5th Aug 2019

To
The Director,
Chander Priya Educational Society,
38, Indra Palli, Palace Compound West,
Agartala, Tripura (W).

Subject: - No Objection Certificate.

With reference to your compliance report under no. & dated nil, it is hereby certified that the building premises as per description below has been inspected by the officer concerned of this department on 05/08/2019 in respect of implementation of fire safety measures and it was found that said building has complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of West Bengal Fire Services Act, and the Part-IV of the latest National Building Code in force in Tripura. The premises/building is declared fit for occupancy with effect from 05/08/2019 for a period of One year subject to compliance of the conditions for the validity of Fire NOC.

1. Name & address of the proposed building / premises: - Agartala International School, Chander Priya Educational Society, Priya Tilla, Chandimari, Agartala, Tripura (W).

Issued on 5-8-2019 at Agartala.

Joint Director
Tripura Fire Service

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction / projection.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to :-

1. The Divisional Fire Officer, West Division, Agartala for information. This has a reference to his letter vide No.4835/3-8/FIRE(W)/2019 dated 09.07.2019.
2. OC, Agartala Fire Station for favour of Information.

***** WE SERVE TO SAVE *****

Nabamita Dey Acharya
Principal
The Agartala International School
Priya Tilla, East Chandimari
Kunjaban Agartala-6